

**TAMIL NADU FIRE AND RESCUE SERVICES DEPARTMENT**

**FIRE SAFETY CERTIFICATE**

**VILLIVAKKAM FIRE & RESCUE SERVICES STATION**

Ref No: 12/2026

Office Ref No: 50/V/VLK/2026

Date: 20.02.2026

**Subject :** Fire and Rescue Services Department – Villivakkam Fire Station – Issuance of Fire Safety Certificate to the School – Regarding.

**References:** 1. Government Order No.122, School Education (2) Department, dated 14.09.2004  
2. Government Order No.123, School Education (2) Department, dated 14.09.2004  
3. Application received from **THE PRINCIPAL**, dated **19.02.2026**

With reference to the Government Orders and the application cited above, an inspection was conducted on 20.02.2026 by the Station Officer Thiru A. Ramachandaran at **M/S ICF VIDYANIKETAN SCHOOL** at **APPRENTICE AVENUE, ICF COLONY, KONNUR HIGH ROAD, CHENNAI - 600 038**. The school building has been inspected and is found suitable for issuance of Fire Safety Certificate, subject to the following conditions. This certificate is valid for One year from **20.02.2026 to 19.02.2027**. There is no objection from the Fire & Rescue Services Department.

**Conditions**

1. This Fire Safety Certificate is valid only for **One year**.
2. Adequate fire extinguishers conforming to IS 2190:2010 standards must be installed.
3. Fire extinguishers must be placed in visible and easily accessible locations throughout the school.
4. First aid kits with necessary medicines must be readily available in the school.
5. LKG and UKG classes must be conducted only on the ground floor.
6. Emergency contact numbers and details of responsible officers must be displayed prominently on the school notice board and in visible locations.
7. Old electrical wiring must be removed and replaced with new wiring certified under Indian Standards.
8. High-tension electric lines must not pass through or near the school premises. If present, they must be removed immediately.
9. Every year on April 14th, Fire Safety Day must be observed in the school, including fire awareness campaigns and fire safety training in coordination with the Fire & Rescue Services Department.
10. Emergency exit routes must be provided on all floors for safe evacuation.
11. Classrooms accommodating more than 45 students must have at least two exits.
12. All doors must open outward.
13. Gas pipeline connections must not be concealed within walls.
14. Staircase steps must have a minimum width of 30 cm and height of 15 cm.

15. Staircases and exit pathways must have proper lighting with independent power supply.
16. Miniature Circuit Breakers (MCB) / Earth Leakage Circuit Breakers (ELCB) must be installed.
17. The building must be equipped with proper lightning protection system.
18. If Government regulations or the above conditions are violated, the issued Fire Safety Certificate will automatically stand cancelled.



To:

**The Principal**  
M/S ICF VIDYANIKETAN SCHOOL,  
APPRENTICE AVENUE, ICF COLONY,  
KONNUR HIGH ROAD, CHENNAI - 600 038.

*Handwritten signature*  
**நீலைய அலுவலர்**  
தீயணைப்பு மற்றும் மீட்டிங் பணிகள் நீலையர்  
விலிவாக்கம், சென்னை-600 049.

Copy to: District Officer, Chennai District